

**DEVELOPMENT SERVICES-BUILDING DIVISION  
ANNUAL NIGHT CLUB INSPECTIONS REPORT  
FY 2017 - 2018**

LOCATION/ADDRESS	TRADE	INSPECTOR	DATE	# HOURS	RESULT	COMMENTS
CHAPULTEPEC MEXICAN BAR & RESTAURANT 23 N.W. 2ND AVE	BUILDING:	O. BROOKINS	6/20/2018	1	FAIL	CLEAN OUT MECHANICAL ROOM
	MECHANICAL:	P. BEAUDOIN	6/20/2018	1	PASS	
	ELECTRICAL:	G. LIND	6/20/2018	1	FAIL	REPLACE GFI RECEPTICLES IN KITCHEN
	PLUMBING:	R. STEWART	6/20/2018	1	PASS	AND THROUGHOUT DINING AREA
TATIANA 1710 E. HALLANDALE BEACH BLVD.	BUILDING:	O. BROOKINS	6/22/2018	1	FAIL	CLEAR STORAGE FROM PATH OF EGRESS
	MECHANICAL:	P. BEAUDOIN	6/22/2018	1	PASS	INSTALL GFI OR COVER ELC BOX @ KITCHEN
	ELECTRICAL:	G. LIND	6/22/2018	1	FAIL	REMOVE EXT. CORDS AT KITCHEN
	PLUMBING:	R. STEWART	6/22/2018	1	PASS	PROVIDE 3 FT CLEARANCE AT ELEC PANEL
FLANNIGAN'S SEAFOOD BAR AND GRILL 4 N. FEDERAL HIGHWAY	BUILDING:	O. BROOKINS	6/21/2018	1	PASS	NO STORAGE WITHIN 3 FEET OF ELEC PANEL
	MECHANICAL:	P. BEAUDOIN	6/21/2018	1	PASS	REMOVE EXT CORD AT PATIO INSTALL GFIs
	ELECTRICAL:	G. LIND	6/21/2018	1	FAIL	AT KITCHEN
	PLUMBING:	R. STEWART	6/21/2018	1	PASS	
GULFSTREAM PARK FOOD & BEVERAGE-ORCHID CONCES ORCHID CONCESSIONS, INC. 901 S. FEDERAL HIGHWAY	BUILDING:	O. BROOKINS	6/21/2018	1	FAIL	REMOVE CARTS IN EXIT PATH
	MECHANICAL:	P. BEAUDOIN	6/21/2018	1	PASS	
	ELECTRICAL:	G. LIND	6/21/2018	1	FAIL	REMOVE EXTENSION C ORDS JOKERS WILD
	PLUMBING:	R. STEWART	6/21/2018	1	PASS	AND FERRELLS BAR INSTALL GFI RECEPTICLES AT THE FINISH LINE BAR
OCEAN'S 11 LOUNGE SOUTH 800 N. FEDERAL HIGHWAY	BUILDING:	O. BROOKINS	6/21/2018	1	PASS	
	MECHANICAL:	P. BEAUDOIN	6/21/2018	1	PASS	
	ELECTRICAL:	G. LIND	6/21/2018	1	PASS	NO ELEC. LIFESAFETY HAZ. OBSERVED
	PLUMBING:	R. STEWART	6/21/2018	1	PASS	GREASETRAP MAINT/HEALTH DEPT-RPT

**DEVELOPMENT SERVICES-BUILDING DIVISION  
ANNUAL NIGHT CLUB INSPECTIONS REPORT  
FY 2017 - 2018**

UPPERDECK PROPERTIES 906 E. HALLANDALE BLVD	BUILDING: MECHANICAL: ELECTRICAL: PLUMBING:	O. BROOKINS P. BEAUDOIN G. LIND R. STEWART	6/20/2018 6/20/2018 6/20/2018 6/20/2018	1 FAIL 1 PASS 1 FAIL 1 PASS	BULB BURNED OUT AT EXIT SIGN AT REAR OF CHEECKI HUT  GFI RECEPTICLES AT BAR
FATE 601 SILKSRUN SUITE 2499	BUILDING: MECHANICAL: ELECTRICAL: PLUMBING:	O. BROOKINS P. BEAUDOIN G. LIND R. STEWART	6/21/2018 6/21/2018 6/21/2018 6/21/2018	1 PASS 1 PASS 1 PASS 1 PASS	NO ELEC. LIFESAFETY HAZ. OBSERVED GREASETRAP MAINT/HEALTH DEPT-RPT
THE CHEETA 100 ANSIN BLVD	BUILDING MECHANICAL ELECTRICAL PLUMBING	O. BROOKINS P. BEAUDOIN G. LIND R. STEWART	6/21/2018 6/21/2018 6/21/2018 6/21/2018	1 PASS 1 PASS 1 FAIL 1 PASS	REPLACE WITH GFI IN KITCHEN
THE BIG EASY CASINO 831 FEDERAL HIGHWAY	BUILDING MECHANICAL ELECTRICAL PLUMBING	O. BROOKINS P. BEADOIN G. LIND R. STEWART	6/22/2018 6/22/2018 6/22/2018 6/22/2018	1 PASS 1 PASS 1 PASS 1 PASS	