

**CITY OF HALLANDALE BEACH**  
 FY20-21 Nightclubs Inspections.

Name	Discipline			
	Structural	Electrical	Plumbing	Mechanical
Chapultepec Mexican Bar and Restaurant	P	P	P	P
Fate	Must Repair / Replace Panic Hardware @ Rear Exit	P	P	P
Flanigan's Seafood Bar and Grill	P	NEC 210.8 GFCI protection required in kitchen and within 6' of all sinks.	P	P
Orchid Concessions, Inc. (Gulfstream Park Food and Beverage)	P	P	P	P
831 Federal Highway Acquisition, LLC. / The Big Easy Casino	P	P	P	P
Ocean's 11 Lounge South	P	P	P	P
Tatiana Restaurant and Nightclub	P	P	P	P
The Cheetah	P	NEC 210.8 GFCI protection required in kitchen and within 6' of all sinks.	P	P
<b>Legend:</b>	P = Passed			