

## EXHIBIT 10

### SW SCHOOL SEWER CAPACITY IMPROVEMENTS COST

Development Name		Sewer Collection and Transmission System Area	Capacity to Build Number of GPM (Gallons per minute)	
SW 11 Street School		West	65	
Demand Size Calculations				
Category	SF or Nr. of ERU	Nr. of GPD per day/SF	Total GPD	Total GPM
Office		0.15	4,725	3.28
Commercial		0.10	0	0.00
Restaurant			0	0.00
Residential (ERU)		350	0	0.00
Other			0	0.00
Total Gallons			0	3.28
Share Cost Calculation				
Area	Total GPM	System Cost per area	Percentage Share	Share Cost
West	3.28	\$941,000.00	5.05%	\$47,502
	Share Cost	SW 11 Street School	\$47,502	