

DEVELOPMENT SERVICES-BUILDING DIVISION
ANNUAL NIGHT CLUB INSPECTIONS REPORT
FY 2016-2017

EXHIBIT "8"

LOCATION/ADDRESS	TRADE	INSPECTOR	DATE	# HOURS	RESULT	COMMENTS
CHAPULTEPEC MEXICAN BAR & RESTAURANT 23 N.W. 2ND AVE	BUILDING:	MANNY A.	6/9/2017		1 PASS	
	MECHANICAL:	G. CORCUERA	6/1/2017		1 PASS	
	ELECTRICAL:	E. CRUCET	6/1/2017		1 PASS	NO ELEC. LIFESAFETY HAZ. OBSERVED
	PLUMBING:	R. STEWART	6/9/2017		1 PASS	GREASETRAP MAINT/HEALTH DEPT-RPT
TATIANA 1710 E. HALLANDALE BEACH BLVD.	BUILDING:	MANNY A.	6/12/2017		1 PASS	
	MECHANICAL:	G. CORCUERA	6/1/2017		1 PASS	
	ELECTRICAL:	E. CRUCET	6/1/2017		1 FAIL	REMOVE EXT. CORDS/CLEARANCE @ELEC
	PLUMBING:	R. STEWART	6/12/2017		1 PASS	GREASETRAP MAINT/HEALTH DEPT-RPT
FLANNIGAN'S SEAFOOD BAR AND GRILL 4 N. FEDERAL HIGHWAY	BUILDING:	MANNY A.	6/9/2017		1 PASS	
	MECHANICAL:	G. CORCUERA	6/1/2017		1 PASS	
	ELECTRICAL:	E. CRUCET	6/1/2017		1 FAIL	EXIT SIGNS/LABELS/CLRNC @E.PNLS
	PLUMBING:	R. STEWART	6/9/2017		1 PASS	GREASETRAP MAINT/HEALTH DEPT-RPT
GULFSTREAM PARK FOOD & BEVERAGE-ORCHID CONCES ORCHID CONCESSIONS, INC. 901 S. FEDERAL HIGHWAY	BUILDING:	MANNY A.	6/9/2017		1 PASS	
	MECHANICAL:	G. CORCUERA	6/1/2017		1 PASS	
	ELECTRICAL:	E. CRUCET	6/9/2017		1 PASS	NO ELEC. LIFESAFETY HAZ. OBSERVED
	PLUMBING:	R. STEWART	6/9/2017		1 PASS	GREASETRAP MAINT/HEALTH DEPT-RPT
HOLLYWOOD CONCESSIONS, INC/MARDI GRAS 831 N. FEDERAL HIGHWAY	BUILDING:	MANNY A.	6/13/2017		1 PASS	
	MECHANICAL:	G. CORCUERA	6/1/2017		1 PASS	
	ELECTRICAL:	E. CRUCET	6/5/2017		1 PASS	NO ELEC. LIFESAFETY HAZ. OBSERVED
	PLUMBING:	R. STEWART	6/13/2017		1 PASS	GREASETRAP MAINT/HEALTH DEPT-RPT
OCEAN'S 11 LOUNGE SOUTH 800 N. FEDERAL HIGHWAY	BUILDING:	MANNY A.	6/12/2017		1 PASS	
	MECHANICAL:	G. CORCUERA	6/1/2017		1 PASS	
	ELECTRICAL:	E. CRUCET	6/1/2017		1 PASS	NO ELEC. LIFESAFETY HAZ. OBSERVED
	PLUMBING:	R. STEWART	6/12/2017		1 PASS	GREASETRAP MAINT/HEALTH DEPT-RPT

DEVELOPMENT SERVICES-BUILDING DIVISION
ANNUAL NIGHT CLUB INSPECTIONS REPORT
FY 2016-2017

UPPERDECK PROPERTIES 906 E. HALLANDALE BLVD	BUILDING:	MANNY A.	6/12/2017	1 PASS	
	MECHANICAL:	G. CORCUERA	6/1/2017	1 PASS	
	ELECTRICAL:	E. CRUCET	6/1/2017	1 FAIL	LABELS@E.PNLS/ CLRNCE@E.PNLS
	PLUMBING:	R. STEWART	6/9/2017	1 PASS	GREASETRAP MAINT/HEALTH DEPT-RPT
GULFSTREAM PARK RACING ASSOC.-FATE 601 SILKSRUN SUITE 2499	BUILDING:	MANNY A.	6/9/2017	1 FAIL	NO ACCESS
	MECHANICAL:	G. CORCUERA	6/1/2017	1 FAIL	NO ACCESS
	ELECTRICAL:	E. CRUCET	6/7/2017	1 FAIL	NO ACCESS
	PLUMBING:	R. STEWART	6/9/2017	1 FAIL	NO ACCESS
GULFSTREAM PARK RACING ASSO. SOC.-MARTINI BAR 601 SILKS RUN SUITE 2497	BUILDING:	MANNY A.	6/9/2017	1 PASS	
	MECHANICAL:	G. CORCUERA	6/1/2017	1 PASS	
	ELECTRICAL:	E. CRUCET	6/7/2017	1 PASS	NO ELEC. LIFESAFETY HAZ. OBSERVED
	PLUMBING:	R. STEWART	6/9/2017	1 PASS	GREASETRAP MAINT/HEALTH DEPT-RPT
ADENA GRILL/FRANKEY'S 900 SILKS RUN BLDG 1700	BUILDING:	MANNY A.	6/9/2017	1 PASS	
	MECHANICAL:	G. CORCUERA	6/1/2017	1 PASS	
	ELECTRICAL:	E. CRUCET	6/9/2017	1 PASS	NO ELEC. LIFESAFETY HAZ. OBSERVED
	PLUMBING:	R. STEWART	6/9/2017	1 PASS	GREASETRAP MAINT/HEALTH DEPT-RPT
THE CHEETAH 100 ANSIN BLVD 2497	BUILDING:	MANNY A.	6/12/2017	1 PASS	
	MECHANICAL:	G. CORCUERA	6/12/2017	1 PASS	
	ELECTRICAL:	E. CRUCET	6/12/2017	1 PASS	NO ELEC. LIFESAFETY HAZ. OBSERVED
	PLUMBING:	R. STEWART	6/12/2017	1 PASS	GREASETRAP MAINT/HEALTH DEPT-RPT