

City of Hallandale Beach City Commission Agenda Cover Memo

Meeting Date:		Item Type:			1 st Reading		2 nd Reading	
3/3/2021		☑ Resolution☐ Ordinance☐ Other		Ordinance Reading	N/A		N/A	
				Public Hearing				
File No.:				Advertising Required				
20-011				Quasi Judicial:				
Fiscal Impact (\$):		Account Balance (\$):		Funding Source:	Proje		ct Number :	
\$262,120		\$883,764		3660-546080	60-546080		P2116	
Contract/P.O. Required		RFP/RFQ/Bid Number:		Sponsor Name:		Department:		
⊠ Yes	□ No	City of Fort Lauderdale ITB 473-11907 – Project 1220		Jeff Odoms, Interim Director		Public Works		
Strategic Plan Focus Areas:								
☐ Finance & Budget			☐ Organizational Capacity			⊠ Infrastructure/Projects		
Implementation Timeline:								
Estimated Start Date: 2/3/2021 Estimated End Date: 9/30/2121								

SHORT TITLE:

A RESOLUTION OF THE MAYOR AND CITY COMMISSION OF THE CITY OF HALLANDALE BEACH, FLORIDA, AUTHORIZING UTILIZATION OF THE CITY OF FORT LAUDERDALE'S CONTRACT WITH HINTERLAND GROUP, INC., FOR MAINTENANCE OF LARGE DIAMETER STORM WATER PIPES IN AN AMOUNT NOT TO EXCEED TWO HUNDRED SIXTY TWO THOUSAND, ONE HUNDRED TWENTY DOLLARS (\$262,120); AUTHORIZING CITY MANAGER TO EXECUTE RELATED DOCUMENTS; AND PROVIDING AN EFFECTIVE DATE.

STAFF SUMMARY:

Summary:

This agenda item seeks City Commission's approval to retain the services of Hinterland Group, Inc. for the maintenance of large diameter storm water pipes utilizing the City of Fort Lauderdale's contract with Hinterland Group, Inc. through Invitation to Bid (ITB) No. 473-11907 (Exhibit 3) for an amount not-to exceed \$262,120.

Background:

Stormwater systems, often as a part of their operation, accumulate silt and debris over time. The infrastructure where this accumulation occurs is underground and requires a large scale operation to effectively perform the cleaning.

While the City of Hallandale Beach has been routinely maintaining and cleaning the smaller diameter (15" and under) storm water pipes, City staff was never equipped nor had in place any means to clean the larger diameter pipe in the drainage system. The accumulation of debris and sediments inside these pipes reduces the effective flow of stormwater, which increases the opportunity of flooding hazards during rainy seasons.

Current Situation:

The stormwater pumping station located in the NE section of the city connects to a 60 inch diameter piping system. This piping system runs north to south on NE 14th Avenue, from Hallandale Beach Blvd to Atlantic Shores Boulevard. Hinterland Group will be performing the work and it will involve plugging the system in sections, desilting it, and inspect it for any repairs that may be needed. Hinterland Group, Inc. submitted the attached proposal for an amount of \$262,120 (Exhibit 2).

The term of the original contract (Exhibit 3) expired on June 9, 2019. The City of Fort Lauderdale has exercised its right to extend the contract with Hinterland Group, Inc. for the two (2) one (1) year renewal term stipulated in Section 15. 1 of the contract; which extends the contract term to June 19, 2021 (Exhibit 4).

Cost Benefit

The performance of this maintenance increases the efficiency of the system to remove stormwater from the area. It increases the opportunity to mitigate flooding in the area, and reduces impacts to the homeowners. Additionally, performing this work is necessary to allow the stormwater system to reach its designed life span.

PROPOSED ACTION:

City Commission to approve the attached resolution and authorize staff to retain the services of Hinterland Group, Inc. for the maintenance of large diameter stormwater pipe in the specified area utilizing the City of Fort Lauderdale's agreement with Hinterland Group, Inc. through the Invitation to Bid (ITB) No. 473-11907 for an amount not-to exceed \$262,120.

ATTACHMENT(S):

Exhibit 1 – Resolution

Exhibit 2 – Proposal 20-0194-01- Hallandale - NE 14th Ave Cleaning

Exhibit 3 – Ft. Lauderdale Contract

Exhibit 4-- Ft. Lauderdale Contract Extension

Prepared By: <u>Jeff Odoms</u>

Jeff Odoms

Interim Director of Public Works

Reviewed By: Mary Francis Jeannot

Mary Francis Jeannot

Assistant Director of Public Works/Administration

Approved By: Assistant City Manager

Keven Klopp

Assistant City Manager