



Hallandale Beach Water and Wastewater Improvements for Future Growth

January 7, 2026

Agenda

Part 1: Water


Part 2: Wastewater

Part 1: Water

The City's water plant uses two treatment technologies

Technology 2:
Nanofiltration
Membranes

Technology 1:
Lime Softening



The City's existing WTP has two treatment processes

1

Lime Softening



Early 1900s Technology
Built in 1950

Design Capacity: 10 mgd

2

Membrane Treatment



State-of-the-Art Technology
Built in 2007

Design Capacity: 6 mgd
(expandable to 13 mgd)

Water plant current design capacity is 16 mgd

Lime Softening
Design Capacity
= 10 mgd



Membrane Treatment
Design Capacity
= 6 mgd



16 mgd

Are we allowed to
produce 16 mgd?

No

Why?

Two key factors determine how much drinking water the City can produce...

1. Raw Water Permit Allocation





2. Treatment Technology Used

Current
Biscayne
Allocation =
8.29 mgd



Where does the City's water supply come from?

Biscayne Aquifer
Occurs Just Below Land Surface
(City's existing supply)



The City has Two Sources of Biscayne Aquifer Water

1 City Wells





City owns five wells

2 Broward County Wells



Water received via a pipeline

The City's use of the Biscayne Aquifer is limited by its Water Use Permit



City's Biscayne Aquifer withdrawal allocation
 $= 4.03 + 4.26 = 8.29 \text{ mgd}$

Can the City's Biscayne Aquifer withdrawal allocation be increased above 8.29 mgd to meet future demands?

The Biscayne Aquifer is fully allocated.

No increase in Biscayne Aquifer withdrawal allocation is feasible.


The amount of drinking water that can be produced depends on the treatment technology...

City Wells

4.03
mgd

Raw Water

Lime Softening



Drinking Water




98%

Broward County

4.26
mgd

Raw Water

NF Membrane



Drinking Water




85%

What is the maximum amount of drinking water the City can currently produce?


Drinking Water from
Lime Softening



Drinking Water from
Membranes




Total Drinking Water



7.5 mgd is an Average Value. On any single day, the City can produce up to the maximum design capacity of our treatment infrastructure. Daily values averaged over one year cannot exceed 7.5 mgd.

The current treatment and supply infrastructure can meet the City current water demand as evidenced by the below

Current Average
Day Drinking Water
Production Capacity



Current Average
Day Drinking Water
Demand



6.5 to 6.9
mgd

7.5 mgd is greater than 6.9 mgd. Hence, the City has sufficient treatment capacity to meet current demand.

The City's water plant needs to be able to support its expected growth to year 2050 buildout population...



Year 2050 Average Day Drinking Water Demand Estimate

The City can also purchase water from North Miami Beach if there is a emergency



Hallandale Beach Owned Pump Station
(emergency interconnect with NMB)



Estimated buildout population is 60,569 in the year 2050


Year	2019 Water Use Permit (WUP) Forecast	2024 Broward County Population Forecast Allocation Model (PFAM)	Percent Difference
2025	42,110	43,109	2.4%
2030	43,574	47,886	9.9%
2035	44,696	50,241	12.4%
2040	45,818	54,687	19.4%
2045	46,782	57,657	23.2%
2050	47,745	60,569	26.9%

Old Forecast
(for reference)

Current Forecast

Drinking Water Demand Forecast


The City needs to increase its treatment capacity to meet Year 2050 demand (i.e., buildout population)



What treatment capacity do we need to meet the year 2050 demand for the buildout population of 60,569?



2050 Demand Estimate



Minimum capacity is
12 mgd
(11.4 mgd rounded up)



The City has developed an investment plan to deliver the above capacity.

There are two other factors that require the City to invest in water treatment and supply infrastructure

Lime Softening



1. The lime softening treatment infrastructure is at the end of its useful life.
2. PFAS Rule (compliance required by late 2028*)

The lime softening treatment infrastructure is at the end of its useful life



Treatment Infrastructure: The lime softening treatment infrastructure age ranges from 58 to 75 years old. Many elements are near the end of their useful life. Certain infrastructure, for example filters 7-10, are no longer operational.



Support Infrastructure: The City has made significant investments in its support infrastructure in recent years. For example, it replaced its high service pump station which will serve the City for many decades to come.

What is the PFAS Rule?

PFAS are chemicals that are present in thousands of products



Non-stick Coatings

Examples



Fire Fighting Foam




Food Wrappers

EPA's "Forever Chemical" Rule Issued April 2024



The City must
invest in treatment
changes to comply
with the PFAS rule
by late 2028

The City's water supply exceeds the “Forever Chemicals” (a.k.a., PFAS) drinking water standard



PFAS in City's Water Supply

City must comply with PFAS Rule by late 2028

1 ppt = Imagine one drop of ink in a volume of water equivalent to 20 Olympic-sized swimming pools

What does the City need to do to comply with the PFAS Rule?

Lime Softening



Lime softening must be discontinued

Does not remove PFAS

Membrane Treatment



Removes PFAS

...the City has decided to transition to 100% membrane treatment to comply with the PFAS Rule.


The City has developed a comprehensive plan for PFAS compliance

Planning



The City has completed a study to determine its options

Design




The City will engage its consultants to design treatment and supply improvements

Permitting



Extensive permitting will be required

Construction



The City's CIP includes appropriate budget to fund PFAS compliance

How will transitioning to 100% membrane treatment impact the City's ability to meet water demand?

100% Membrane Treatment



Removes PFAS

Current Average Day
Drinking Water Demand




6.5 to 6.9
mgd

How much drinking water can the existing membrane plant produce?

How much drinking water can the existing membrane plant produce?

Existing
Membrane
Building
Floor Plan





Skid	Design Capacity (mgd)
NF Skid 1	3
NF Skid 2	3
RO Skid 1	2
Total	8

Can the City
produce this much?

On any single day yes.
However, our annual
average must comply with
our water use permit.

The amount of drinking water that can be produced from the existing WTP depends on the treatment technology and our water use permit




The annual average production capacity of the existing membrane plant is 5.6 mgd


Drinking Water from
NF Membranes



Drinking Water from
RO Membranes



Total Drinking Water



Annual average demand is 6.5 to 6.9 mgd. Hence, two things need to happen:

1



Expand
WTP


2




Coordinate with NMB
for supplemental water

The City's membrane plant expansion includes multiple phases


Existing Membrane Plant Floor Plan



Phase 1: RO Skid 2 by late 2028



Phase 2: RO Skid 3 by ≈ 2030




Phase 1 ensures compliance with PFAS Rule

Phase 2 ensures adequate water to meet demand for the year 2050 buildout population

The City's membrane plant expansion includes multiple phases

Phase 1: RO Skid 2




Phase 1 ensures compliance with the PFAS Rule


Phase 1: Addition of RO Skid 2 (currently being designed)

Phase 1 Results: annual average production capacity increased to 7.0 mgd

City Wells RO Membranes Drinking Water




Broward County NF Membranes Drinking Water



Phase 1 will allow the City to meet current average day and maximum day demand conditions and comply with the PFAS Rule

Drinking Water from
NF Membranes




Meets PFAS
Rule?



Yes

Drinking Water from
RO Membranes




Meets Current
Demand?



Yes

Total Drinking Water



Supplemental Water
Needed?




No

What treatment capacity do we need to meet the year 2050 demand for the buildout population of 60,569?



2050 Demand Estimate




Minimum capacity is
12 mgd
(11.4 mgd rounded up)



The City plans to invest in the Upper Floridan Aquifer (UFA) to ensure it can meet the year 2050 water demand.

The City's membrane plant expansion includes multiple phases

Phase 2: RO Skid 3




Phase 2: Addition of RO Skid 3 (currently being planned)

Phase 2 ensures the City can meet the year 2050 buildout demand


Phase 2 Results: annual average production capacity increased to 10.0 mgd

City BA Wells RO Membranes Drinking Water


BA: Biscayne Aquifer
FAS: Floridan Aquifer



City FAS Wells RO Membranes Drinking Water




Broward County NF Membranes Drinking Water



Phase 2 will allow the City to meet the year 2050 buildout water demand

Drinking Water from
NF Membranes




Meets PFAS
Rule?



Yes

Drinking Water from
RO Membranes




Meets Year 2050
Demand?



Yes

Total Drinking Water



Supplemental Water
Needed?



No

Final Summary of Demand vs Production Capacity

Average Day Demand		Finished Water Average Day Production Capacity			
		Existing WTP Using Lime Softening and Membranes	Existing WTP After Transition to 100% Membranes	After Membrane Plant Expansion Phase 1	After Membrane Plant Expansion Phase 2
Description	Value				
Current Average	6.9 mgd				
Planned Development	1.2 mgd				
Additional for 2050 Buildout Population	1.6 mgd				
TOTAL (year 2050)	9.7 mgd	7.5 mgd	5.6 mgd	7.0 mgd	10.0 mgd




City's plan
meets the year
2050 demand? Yes

What is the Upper Floridan Aquifer?

The Upper Floridan Aquifer (UFA) is 1,000 to 1,500 feet below ground that contains brackish water


Brackish \approx 3,000 to 5,000 part per million dissolved solids (TDS)

For comparison, ocean water salinity \approx 35,000 ppm TDS



South Florida utilities that use the Upper Floridan Aquifer for water supply, for example:

Current UFA Users



Future UFA Users



Others not shown for brevity

This transition requires investing in two
Floridan Aquifer water supply wells

The City
investigated
eight potential
site. These
two are the
most cost-
effective.



What does a water supply well look like?




Photo of Hallandale Beach Well PW-9 (Biscayne Aquifer Well)

Addition of Generator 2 is also planned to support the treatment capacity expansion

Location Map




Generator Building Floor Plan



Construction of Deep Injection Well 2 may also be needed to support the planned treatment capacity expansion

Location Map



Deep Injection Well 1




The deep injection well (DIW) is used to dispose of the “concentrate” (brine) produced by the membrane treatment process

The City is actively developing work authorizations with its consultants to deliver designs to enable the treatment capacity increase

Work Authorization	Project	Reason this Work is Necessary
1	Optimal Corrosion Control Treatment Pilot Test	PFAS compliance, discontinuation of LS requires adjustments to stabilization chemicals
2	Water Treatment Plant Master Plan	PFAS compliance, capacity increase
3	Chemical Stabilization Improvements Design through CMS	PFAS compliance, discontinuation of LS requires adjustments to stabilization chemicals
4	Floridan Aquifer Wells Design through CMS	Capacity increase
5	Equip Floridan Aquifer Wells	Capacity increase
6	Floridan Aquifer Pipeline	Capacity increase
7	Reverse Osmosis (RO) Pilot Test	Capacity increase
8	RO Skid 3 Design through CMS	Capacity increase
9	Emergency Power - Generator 2 Addition	Capacity increase
10	Deep Injection Well No. 2 and/or SS Force main	City is limited to operating one skid during mechanical integrity testing of the DIW every five years

After RO Skid 3 is operational and the chemical upgrades are complete, the City can demolish certain lime softening plant infrastructure to free up space

Lime sludge can be discontinued once the “Optimal Corrosion Control Treatment Pilot Test” is complete and the “Chemical Stabilization Improvements” are constructed



Lime softening infrastructure that can be removed

Part 2: Wastewater

City's wastewater system overview

15 City Owned
Lift Stations



12 Miles of
Force Mains



57 Miles of
Gravity Sewer




The City collects and pumps wastewater to the City of Hollywood South Regional Wastewater Treatment Plant (SRWWTP) as a “Large User”

SOUTHERN REGIONAL WASTEWATER TREATMENT PLANT July 2025 Large User Capacity Report (GPD)							
Large User	Encumbered Flow*	Annual Average Daily Flow / Last 12 Months	Total Flow AADF + Enc.	Capacity** Allocations	% of Cap Used	% of Cap Used or Encumbered	Available Capacity
Broward County	909,542	3,812,247	4,721,789	5,883,000	64.80%	80.26%	1,161,211
Dania Beach	1,196,955	3,829,545	5,026,500	5,217,000	73.41%	96.35%	190,500
Hallandale Beach	689,518	7,469,408	8,158,927	8,713,500	85.72%	93.64%	554,573
Hollywood	1,562,309	20,695,14	22,258,052	21,811,500	94.88%	102.05%	-446,552
Miramar ***	0	143,704	143,704	1,665,000	8.63%	8.63%	1,521,296
Pembroke Park	101,475	928,900	1,030,375	1,110,000	83.68%	92.83%	79,625
Pembroke Pines	266,401	7,504,452	7,770,853	11,100,000	67.61%	70.01%	3,329,147
Total	4,726,200	44,384,000	49,110,200	55,500,000			6,389,800

City's current average flow to SRWWTP = 7.5 mgd

The City's wastewater flows increase as a function of population growth and system deterioration (a.k.a., “inflow / infiltration”)




- Flows vary by year based on inflow / infiltration (I/I)
- I/I is influenced by weather – peaks may be due to “wet” years

The City's reserved capacity at SRWWTP is 8.7135 mgd



City of Hollywood
Southern Regional
Wastewater
Treatment Plant
(SRWWTP)



The City has 1.2 mgd of remaining reserve capacity

Current average flow to SRWWTP (A) : 7.5 mgd

City's reserved capacity at SRWWTP (B): 8.7135 mgd

Current remaining reserve capacity: (B) – (A) = 8.7135 mgd - 7.5 mgd = 1.2 mgd

Current remaining reserve capacity: 1.2 mgd

The City currently has sufficient capacity.
How much will we need to meet future demands?

Multiple development projects are in various stages of planning; these projects will increase the City's wastewater flow

Major Development Projects on Review



0.11 mgd

Major Development Projects with Approved Site Plans



0.26 mgd

Major Development Projects Under Construction or Building Permit Review



0.82 mgd

Near-Term Development



1.2 mgd


How much additional wastewater capacity will we need over the long-term (i.e., Year 2050 buildout)?

Near-Term Development



1.2 mgd

Additional Needed at Year 2050 Buildout



Buildout Population
60,569



2.3 mgd

Total Additional Wastewater Capacity Needed to Meet Year 2050 Buildout Population



3.5 mgd

Total wastewater capacity needed at year 2050 buildout population is 11.0 mgd

Current Average Flow to SRWWTP

7.5 mgd

Total Additional Wastewater Capacity Needed to Meet Year 2050 Buildout Population

3.5 mgd

Total Wastewater Capacity Needed at Year 2050 Buildout Population

11.0 mgd

$$7.5 \text{ mgd} + 3.5 \text{ mgd} = 11.0 \text{ mgd}$$

The City's available reserve capacity of 8.7135 mgd is not sufficient to meet the year 2050 buildout flow

The City needs to obtain an additional 2.3 mgd of wastewater treatment capacity

Total Wastewater Capacity
Needed at Year 2050 Buildout
Population

Reserve Capacity at
SRWWTP

Treatment Capacity
Shortfall

$$11.0 \text{ mgd} - 8.7 \text{ mgd} = 2.3 \text{ mgd}$$

What is the City's plan to obtain an additional 2.3 mgd of wastewater treatment capacity?

The City is assessing multiple options for additional wastewater capacity needed to meet its year 2050 buildout population

Negotiate with a large user to access available capacity



Status: Ongoing

Study pumping to other systems (MDWASD)




Status: Ongoing

Construct City owned WWTP



Previously studied; proved infeasible

Conveyance of wastewater to MDWASD



- Hazen created the City's wastewater hydraulic model in 2007
- The City is retaining Hazen to update the model with the new wastewater forecast and assess the technical feasibility of conveyance of a portion of the City's wastewater to MDWASD


Partnering with North Miami Beach is also being explored



- The City is in preliminary discussions with the City of North Miami Beach regarding partnering on a new wastewater treatment plant

Final Summary of Wastewater vs Treatment Capacity

Average Day Wastewater Forecast		Wastewater Treatment Capacity		
		Reserve Capacity at SRWWTP [A]	Additional Treatment Capacity Needed [B]	[A] + [B]
Description	Value			
Current Average	7.5 mgd			
Planned Development	1.2 mgd			
Additional 4,000 units	2.3 mgd			
TOTAL (year 2050)	11.0 mgd	8.7 mgd	2.3 mgd	11.0 mgd



The City is exploring options to provide this additional treatment capacity.

Thank you for listening



For more information please visit www.cohb.org

Questions?

Backup Slides


Lime Softening operational challenges at WTP

Four filters (7-10) are out of service per Luis Chiguala
on 10/2/2025

Current lime softening max capacity = 5.5 mgd per Luis
Chiguala on 10/2/2025
(limitation due to the four filters being out of service)

Average Day vs Max Day...what does this mean?

2050 Demand Estimate



Avg Day: The City needs the water supply infrastructure and water use permit that allows it to meet the average day demand.

Max Day: The City needs the water treatment infrastructure that allows it to meet the maximum day demand.

12 mgd (11.4 mgd rounded up)